



**Office of the Chief Fire Officer  
Pune Municipal Corporation**

Out W.No : FB/ 1574  
Date : 5/11/2020

( 760 / 2014 + 632 / 2015 )

To,  
Jagadish Deshpande Architects,  
Apte Road, Pune.

**Sub :- PART Final Fire NOC for the building at S.No.54/5B, 54/2/1, Kharadi, Pune.**  
( For Building B – Height 14.40 Mtrs, 3<sup>rd</sup> floor, Built up – 1525.04 Sq.Mtrs. Only )

Ref :- Your Office letter Dt.26.10.2020

Sir,


As per your request, visited the proposed site along with Mr. Yash Ambole on Dt.29.10.2020 and tested the Hydrant system, Hose Reel system with equipments and portable fire extinguishers suggested in Provisional N.O.C. issued vide No. FB/6568, Dt.01.06.2016 issued by Fire Department.


The suggestions made in Provisional N.O.C. are carried out to my satisfaction and I have No Objection to use the above said part of the building for proposed purpose. Annual Fee is paid by challan No.21948, Dt. 03.11.2020, Rs.2180/- M/s. Gurutech Fire Systems, Pune has submitted the "FORM A" to this office for the fire prevention, protection & fire fighting system installed in the above said building as per The Maharashtra Fire Prevention & Life Safety Measures Act 2006.


The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire fighting system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services or Chief Fire Officer, Pune Fire Brigade. The list of the licence contractor is available on [www.maharashtrafireservices.org](http://www.maharashtrafireservices.org).

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This PART Final No objection is subjected to any other conditions laid by any other department.

  
( Ramesh B. Gangad )  
Assi. Divisional Officer  
Fire Brigade Dept., PMC



  
( Prashant D. Ranpise )  
Chief Fire Officer  
Pune Municipal Corporation

Copy to : Dy. Engineer (B.C.), PMC.

For Kothari International School

  
Manager