



**Office of the Chief Fire Officer
Pune Municipal Corporation**

Out W.No : FB/ 1574
Date : 5/11/2020

(760 / 2014 + 632 / 2015)

To,
Jagadish Deshpande Architects,
Apte Road, Pune.

Sub :- PART Final Fire NOC for the building at S.No.54/5B, 54/2/1, Kharadi, Pune.
(For Building B – Height 14.40 Mtrs, 3rd floor, Built up – 1525.04 Sq.Mtrs. Only)

Ref :- Your Office letter Dt.26.10.2020

Sir,


As per your request, visited the proposed site along with Mr. Yash Ambole on Dt.29.10.2020 and tested the Hydrant system, Hose Reel system with equipments and portable fire extinguishers suggested in Provisional N.O.C. issued vide No. FB/6568, Dt.01.06.2016 issued by Fire Department.


The suggestions made in Provisional N.O.C. are carried out to my satisfaction and I have No Objection to use the above said part of the building for proposed purpose. Annual Fee is paid by challan No.21948, Dt. 03.11.2020, Rs.2180/- M/s. Gurutech Fire Systems, Pune has submitted the "FORM A" to this office for the fire prevention, protection & fire fighting system installed in the above said building as per The Maharashtra Fire Prevention & Life Safety Measures Act 2006.

The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly-renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire fighting system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services or Chief Fire Officer, Pune Fire Brigade. The list of the licence contractor is available on www.maharashtrafireservices.org.

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This PART Final No objection is subjected to any other conditions laid by any other department.


(Ramesh B. Gangad)
Assi. Divisional Officer
Fire Brigade Dept., PMC


(Prashant D. Ranpise)
Chief Fire Officer
Pune Municipal Corporation

Copy to : Dy. Engineer (B.C.), PMC.


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)




KOTHARI INTERNATIONAL SCHOOL
Trustee

Date: 17/09/2020

JAGADISH P. DESHPANDE
architect

To,
The Chief Fire Officer,
Pune Municipal Corporation,
Pune - 411 005.

Sub: Part Final Fire NOC for obtaining Completion Certificate to Building 'B'
(3rd Floor Built up area 1525.04 sq.m) at S. No. 54/5B, 54/2/1, Kharadi, Pune.

- Ref: 1) Revised Provisional Fire NOC obtained from your office vide No. 6568,
dated: 01/06/2016 (Your File No. 760/2014 + 632/2015).
- 2) Part Final Fire NOC obtained from your office vide No. FB/6720,
Dated 13/06/2016 (Your File No. 760/2014 + 632/2015).
- 3) Part Final Fire NOC obtained from your office vide No. FB/1194,
Dated 14/06/2018 (Your File No. 760/2014 + 632/2015).

Sir,

Please find enclosed herewith a copy of sanctioned plan containing floor plans, section & elevation of the above-mentioned project. Plot area is 22015.00 Sq.m. and proposed built-up area of Building 'B' is 10143.90 Sq.m. Height of the said Building is 25.80 m. among this developer had completed Building upto Third Floor (Built up area 1525.04 sqm), the completed built up area is 5907.40 Sq.m. and 14.40 m. height.

Plans for the said buildings are sanctioned by the Pune Municipal Corporation vide Commencement Certificate No. 3244/15; dated 30/12/2015 and Revised Provisional Fire NOC, "Part Final Fire NOC" Ground + First Floor + Second Floor is obtained from your office as referred above. Now developer wants to obtain occupancy certificate from Pune Municipal Corporation for Third Floor of the said building for which your Final Fire NOC is required.

A brief area statement of the said building and other required information in prescribed proforma is enclosed for your reference.

You are, therefore, requested to please issue a part Final Fire 'No Objection Certificate' of your department for the Third Floor of Building 'B'.

Please do the needful at your earliest and oblige.

Thanking you,

Yours sincerely,

(Jagadish P. Deshpande)

- Encl: 1) Proforma.
2) Certified copy of the plan.
3) Xerox copy of Revised Provisional Fire NOC.

..2

PUNE OFF. : A-1, SUCCESS CHAMBERS, 1232, APTE ROAD, PUNE - 411 004. ☎ : 020 - 25631141, 25532182 FAX : 020 - 25532325 E-mail : jagadish_deshpande@rediffmail.com
MUMBAI OFF. : UNIT NO. 4, 'SHRINIWAS' BLDG., 2nd FLR., PLOT NO. 18, LANE NO. 4, SHIVAJI PARK, DADAR (W) MUMBAI - 400 028. ☎ 022 - 24473687 / 24473824

PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



Office of the Chief Fire Officer

Pune Municipal Corporation

Out W.No : FB/ 1194

Date : 14/6/18

(670/2014 + 632/2015)

To,
Jagdish Deshpande Architects,
Apte Road, Pune.

Sub:- PART Final Fire NOC for the building at S.No. 54/5B, 54/2/1, Kharadi, Pune.
(For Building B- Height 10.80 Mtrs., 2nd floor - Built Up area = 1525.04 Sq.Mtrs. Only)

Ref :- Your Office letter DL22.05.2018.

Sir,


As per your above referred request letter, visited the proposed site along with Mr. Jadhav on DL30.05.2018 and tested the Hydrant system, Hose Reel system with equipments portable fire extinguishers and all type of fire fighting system suggested in Provisional N.O.C.FB/6568, DL01.06.2016 issued by Fire Department.


The suggestions made in Provisional N.O.C. are carried out to my satisfaction and I have No Objection to use the part of the building for proposed purpose. Annual Fee is paid by challan No.22022, DL12.06.2018, Rs.1,920/- M/s. Sumit Fire Engineers pvt.Ltd., Pune has submitted the "FORM A" to this office for the fire prevention, protection & fire fighting system installed in the above said building as per The Maharashtra Fire Prevention & Life Safety Measures Act 2006.

The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire fighting system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services or Chief Fire Officer, Pune Fire Brigade. The list of the licence contractor is available on www.maharashtrafireservices.org.

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This Part Final No Objection is subjected to any other conditions laid by any other department.


(Ramesh B. Gangad)
Assi. Divisional Fire Officer
Pune Municipal Corporation


(Prashant D. Rangise)
Chief Fire Officer
Pune Municipal Corporation

Copy to : Asst. Engineer (B.C.)
Pune Municipal Corporation.



FIRE SAFETY CERTIFICATE

No.

Dated: 4/5/19

Certified that the KOTHARI INTERNATIONAL SCHOOL (name of the building or premises) at S.NO. 54/5 B, 54/2/1, KHARADI, PUNE (address) comprised of Two basement(s) and Ground + Two (upper floors) owned/occupied by KOTHARI INTERNATIONAL SCHOOL (SHARDA MANSUKHLAL KOTHARI CHARITABLE TRUST) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 30.05.2018 (date of inspection) in the presence of Mr. Jadhav of Sumit Fire Engineers Pvt Ltd., Pune (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class with effect from 14.06.2018 for a period of ONE years in accordance with rule and subject to compliance of the conditions.

Issued on at by

* Strike out whichever is not applicable.

Signature with Seal : _____

Name

: Prashant D. Ranpise
Chief Fire Officer

Designation

: Pune Municipal Corporation

To

KOTHARI INTERNATIONAL SCHOOLSurvey No. 54, Fountain Road, Down Town,Kharadi, Pune 411 014

(Name & Address of the Institution)

1


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL


Trustee

DEPT. CODE No.63

RI24G101

₹६०० + ₹७२
७४ + ७५

पुणे महानगरपालिका

चलन / पावती दि. ३०/०५/१९

15676

खात्याचे नाव : कान्होदास मंगल

मालकाचे नाव : कोथारी इंटरनॅशनल स्कूल,

पत्ता : पुणे

कामाचा तपशील :

क.नं. ५४५५५, ५४२१९,

खारडी, पुणे

रक्कम ₹

वार्षिक फी

₹००१/-

(७९९-२०)

एकूण ₹


₹००१/-

एकूण रक्कम ₹ नऊशे फक्त

रमेशचंद्र मुलगांड

सहायक मुख्याधिकारी

द्वारे ऑफिस महाराष्ट्र, पुणे, न.पा. शाखा, पुणे-५
वरील निष्ठा संपादन केले. माननीय मुख्याधिकारी.



मुद्रादाम. ११५७ (५०x२२ ममी १००० पुस्तके) ८-१७ - स.सा. ११६

PRINCIPAL

Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



पुणे महानगरपालिका

शिवाजीनगर, पुणे ५.

मुख्य अग्निशमन अधिकारी यांचे कार्यालय,

सेंट्रल फायर स्टेशन, जा. क्र. अशाद/५३८

महात्मा फुले पेठ, दिनांक : ४/५/१९

पुणे-४११ ०४२.

(६७० / २०१४ + ६३२ / २०१५)

प्रति,

मे. कोठारी इंटरनॅशनल स्कूल,

स.नं.५४, फाऊंटन रोड,

खराडी, पुणे १४.

विषय : स.नं.५४/५ब, ५४/२/१, खराडी, पुणे येथील शैक्षणिक इमारतीसाठीच्या अंशतः अंतिम ना हरकत प्रमाणपत्राचे नुतनीकरणाबाबत.

संदर्भ :- १. इकडील अंशतः अंतिम ना हरकत दाखला जा.क्र.एफबी/११९४, दि.१४/०६/२०१८.
२. आपलेकडील दिनांक २६/०४/२०१९ रोजीचा अर्ज.

उपरोक्त विषयांकित ठिकाणच्या १०.८० मी. उंचीच्या शैक्षणिक इमारतीसाठी अग्निशामक दलाने संदर्भ क्र. १ अन्वये अंशतः अंतिम ना हरकत दाखला दिलेला होता. सदर इमारतीसाठी केलेली अग्निशमन यंत्रणा सुस्थितीत व कार्यान्वित असल्याबाबत मे. सुमित फायर इंजिनिअर्स प्रा.लि., पुणे यांनी फॉर्म बी सादर केलेला आहे.

तरी उपरोक्त संदर्भ क्र. २ चे पत्रास अनुसरून या पत्राद्वारे अग्निशामक दलाने विषयांकित ठिकाणच्या इमारतीकरीता संदर्भ क्र. १ अन्वये दिलेल्या अंशतः अंतिम ना हरकत दाखल्याचे नुतनीकरण करण्यात येत असून, सदरील ना हरकत दाखला एक वर्षासाठी ग्राह्य धरण्यात येईल.

(रमेश बी. गांगड)

सहाय्यक विभागीय अधिकारी
अग्निशमन दल, पुणे महानगरपालिका

(प्रशांत दी. रणपिसे)

मुख्य अग्निशमन अधिकारी

पुणे महानगरपालिका

Principal

Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14)
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-403 / RD-381

Date: 28.07.2023

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Shree Samarth Services** having their registration office at **B-605, Central Park Residency, Bhoradewasthi, Moshi, Pune 412105** and their contact details are Office Number: 7720093134 and Email ID: santosh@sssplgroups.com with PAN registration No. ALCPP3812A and GST No. 27ALCPP3812A1ZL to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

M/s. Shree Samarth Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **28.07.2023 to 27.07.2025**

Hatyal
Kiran
Asst Director

Digitally signed
by Hatyali Kiran
Date: 2023.07.29
12:07:29 +05'30'

*License used for submission
of Form B for Kothari International
School Kharadi*

Santosh
Ananda
Panaskar

Digitally signed by
Santosh Ananda
Panaskar
Date: 2023.07.29
00:00:16 +05'30'

Santosh
Shridhar
Warick

Digitally signed by
Santosh Shridhar
Warick
Date: 2023.07.29
20:35:42 +05'30'

(S S Warick)
Director

Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



SHREE SAMARTH SERVICES

Government of Maharashtra Authorised Fire Licence Agency

Register Address: -G.No 37 Flat No B-605, Central Park Residency, Spine Road Moshi - 412105.
Office Address:- Flat No2, Sai Sagar Apartment, Spine Road, Pune 411026 Contact No. : 7720093134 / 36
Web Site - www.sssplgroups.com Email : Santosh@sssplgroups.com, Info@sssplgroups.com
Our Presence : Kolhapur | Goa | Kurkumb | Mumbai

FORM B

(See section 3(3) and rule 4(2))

Certificate by the Licensed Agency regarding the compliance of the Fire Prevention & Life Safety Measures

CERTIFICATE

Certified that We, Shree Samarth Services have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises namely: -

Company Name &Address: -

M/s. KOTHARI INTERNATIONAL SCHOOL
Survey No. 54, Fountain Road, Kharadi, Fountain Road,
Pune, Maharashtra 411014

We further certify that these installation in the above-mentioned buildings are maintained in the good repair and efficient conditions during the period of **01st January-2025 to 30th June-2025**, as required under the provisions of the Maharashtra fire prevention and Life Safety measured Act, 2006 (Mah.III of 2007). The details of inspection of installations carried out by us are mentioned in the report appended herewith.

License No. : MFS-LA/2020/RF-403
: MFS-LA/2020/RD-381

Place : PUNE
Reference : SSS/FB/2025-26//002
Date : 01.07.2025

for Shree Samarth Services

Santosh Ananda Panaskar
Digitally signed by
Santosh Ananda Panaskar
Date: 2025.07.01 10:56:09
+05'30'

Authorized Signatory


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



SHREE SAMARTH SERVICES

Government of Maharashtra Authorised Fire Licence Agency

Register Address: -G.No 37 Flat No B-605, Central Park Residency, Spine Road Moshi – 412105.
Office Address:- Flat No2, Sai Sagar Apartment, Spine Road, Pune 411026 Contact No. : 7720093134 / 36
Web Site - www.sssplgroups.com Email : Santosh@sssplgroups.com, Info@sssplgroups.com
Our Presence : Kolhapur | Goa | Kurkumb | Mumbai


Enclosure to Form-B

SSS/FB/2025-26//002


Date: - 01.07.2025

The observations are as follows

Sr. No	Items	Particulars	Units
1	Main Fire Pump	Make: -Kirloskar Brothers Ltd.	1 No.
		KW: -15 KW	
		Speed: -2900 RPM	
		Electricity Operated	
2	Starter Fire Pump	Make: -Kirloskar Brothers Ltd.	1 No.
		KW:-15 KW	
		Speed:-2900 RPM	
		Electricity Operated	
3	Jockey Fire Pump	Make:-Kirloskar Brothers Ltd.	1 No.
		KW:-5.5 KW	
		Speed:-2900 RPM	
		Electricity Operated	
4	Courtyard Hydrant	80mm*4(2 poles) GI. Ring Main, Hydrant Points, Two way at Gate	1 Set
5	Booster Pump	900 LPM with starter	2 Set
6	Electrical Panel	Electrical panel and two starters	1 No.
7	Hydrant Points	Single Hydrant valve court yard and wet risers	21 Nos.
8	Hose Reel	30 Meter's hose Reel pipe with Drum	12 Nos.
9	Hose Pipe	RRL Type -A hose pipe 63 MM dia. 15 meter long	34Nos.
10	Branch Pipe	SS Branch pipe	20 Nos.
11	Fire Alarm Panel	Model: -Ravel 4 loop addressable panel	1 Nos.
12	MCP (Manual Call Point)	Break Glass type	20 Nos.
13	Hooters	Output module with Hooters	20 Nos.
14	Smoke detector	Addressable Smoke Detectors	387 Nos.
15	Sprinklers	All parking area and all floor Sprinkler provided	704 No's
16	Fire Extinguisher	ABC Type 2 Kg,-9 Kg & Co2 Type, M foam type	48 Nos.


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee



SHREE SAMARTH SERVICES

Government of Maharashtra Authorised Fire Licence Agency

Register Address: -G.No 37 Flat No B-605, Central Park Residency, Spine Road Moshi – 412105.
Office Address:- Flat No2, Sai Sagar Apartment, Spine Road, Pune 411026 Contact No. : 7720093134 / 36
Web Site - www.sssplgroups.com Email : Santosh@sssplgroups.com, Info@sssplgroups.com

Our Presence : Kolhapur | Goa | Kurkumb | Mumbai

PERFORMANCES TEST:

Preventive maintenance and corrective measures to be done periodically as per norms (NBC 2005, BIS standard and Maharashtra Fire Preventive and Life Safety Measures Act, 2006 (Mah, III of 2007) the overall performances of the system are satisfactory and as per NBC regulation.

Note: - Above Mentioned installed equipment are checked for its operational and healthy condition as on date further, the complete fire protection system has been maintained by in-house maintenance team and the respective records are maintained. The records are checked at site and found in order. However, it will be responsibility of the owner / Fire department of client to maintain the system in good working condition 24/7 for 365 days.

For **SHREE SAMARTH SERVICES**

Santosh Ananda
Panaskar

Digitally signed by
Santosh Ananda Panaskar
Date: 2025.07.01 10:56:45
+05'30'

Mr. Santosh Panaskar


PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



KOTHARI INTERNATIONAL SCHOOL

Trustee

SHREE SAMARTH SERVICES

Quarterly Servicing Report

Company :- Kothari InterNational School-Kharadi Pune

AS PER IS 2190 STANDARD FIRE EXTINGUISHERS RECORD MONTH OF JUNE - 2025

Sr. No.	Location	Type	Capacity in Kg / Ltr.	Make	Manufacturing Year	Life of period	Expiry Date	Monthly Inspection Date	Next Inspection Date	HPT Done	HPT Due	Refilling Done	Refilling Due	Remarks
1	Basement Parking	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
2	Basement Parking	M Foam	9 Ltr	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
3	Basement Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
4	Basement Parking Near Pump House	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
5	Basement Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
6	Basement Parking Near Lift	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
7	Bus Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
8	Car Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
9	Car Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
10	Car Parking	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
11	Parking Basement	ABC	4 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
12	Cafeteria	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
13	Upper Parking	ABC	4 Kg	Grap fire	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
14	Upper Parking	ABC	4 Kg	Grap fire	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
15	Upper Parking	M Foam	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
16	Upper Parking	ABC	4 Kg	Grap fire	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
17	Upper Parking	ABC	4 Kg	Safe Pro	2019	15	2034	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
18	Upper Parking	CO2	4.5 Kg	Safe Pro	2019	15	2034	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
19	Upper Parking	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
20	H T Room	CO2	4.5 Kg	Kanex	2019	15	2034	Jun-25	Sep-25	Nov-24	Nov-29	Nov-24	Nov-29	OK
21	H T Room	CO2	4.5 Kg	Kanex	2019	15	2034	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
22	Near D G Room	M Foam	50 Ltr	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK (HOSE PIPE DAMAGE
23	Ground Floor Conference Hall	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
24	Ground Floor Near Pantry	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
25	Reception Outside	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
26	Ground Floor Near Lift	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
27	Ground Floor Near Jr Library	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
28	Ground Floor Near Sick Bay	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
29	Ground Floor Near Day Care Hall	ABC	2 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK

SHREE SAMARTH SERVICES

Campany :- Kothari InterNational School-Kharadi Pune

Quarterly Servicing Report

AS PER IS 2190 STANDARD FIRE EXTINGUISHERS RECORD MONTH OF JUNE - 2025

Sr. No.	Location	Type	Capacity in Kg / Ltr.	Make	Manufacturing Year	Life of period	Expiry Date	Monthly Inspection Date	Next Inspection Date	HPT Done	HPT Due	Refilling Done	Refilling Due	Remarks
30	1st Floor Activity Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
31	1st Floor Near Dance room	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
32	1st Floor Near Boys Rest Room	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
33	1st Floor Near 4-A	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
34	1st Floor Near Lift	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
35	1st Floor Near Boys Rest Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
36	1st Floor Multipurpose hall	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
37	2nd Floor Store Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
38	2nd Floor Science Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
39	2nd Floor Near Lift	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
40	2nd Floor Near Boys Rest Room	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
41	2nd Floor Near Key Board Room	ABC	6 Kg	Safe Pro	2019	10	2029	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
42	2nd Floor Near Key Board Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
43	3rd Floor Activity Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
44	3rd Floor Staff Room	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
45	3rd Floor Near Lift	ABC	4 Kg	Grapp fire	2022	15	2037	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
46	3rd Floor Chemistry Lab outside	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK
47	3rd Floor Chemistry Lab inside	CO2	4.5 Kg	Safe Tap	2022	15	2037	Jun-25	Sep-25	Nov-24	Nov-29	Nov-24	Nov-29	OK
48	3rd Floor Near Store	ABC	2 Kg	Safe Tap	2022	10	2032	Jun-25	Sep-25	Nov-24	Nov-27	Nov-24	Nov-27	OK

Remark- 1) All Fire Extinguisher ABC AND CO2 Condition OK 2) Fire Extinguisher M foam ABC 50ltr hose pipe damage - 1 NOS



Signature of Principal

SHREE SAMARTH SERVICES

Kothari International School

KOTHARI INTERNATIONAL SCHOOL

PRINCIPAL
Kothari International School
Kharadi, Pune (MH)



Signature of Trustee